

Georgia Environmental Protection Division - Underground Storage Tank (UST) Management Program
Public Record Report for FFY 2011

General Information

Public Record Posted Date: December 16, 2011

Total Number of UST Facilities: 9,765
Total Number of USTs: 29,445

Summary Information For Inspections

Number of UST Facilities Inspected: 3,728
Inspection Period Dates Were From: To: 10/01/2010 - 09/30/2011
Percent Compliance (Combined Measure): 67%

Note: Tank, facility, and on-site inspection information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those tanks identified in 40 CFR 280.10(b) as excluded USTs and those deferred in 40 CFR 280.10(c). Inspections measure compliance with EPA SOC for the combined measures of Release Prevention and Realease Detection.

Summary Information for Releases

Number of Confirmed UST Releases: 198
Release Period Dates Were From: To: 10/01/2010 - 09/30/2011

Summary Information for Release Sources And Causes

Source	Cause															
			Spill		Overfill		Phys/Mech		Corrosion		Install		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	8	4%	0	0%	1	13%	0	0%	0	0%	0	0%	0	0%	7	88%
Piping	7	4%	1	14%	0	0%	1	14%	0	0%	0	0%	0	0%	5	71%
Dispenser	3	2%	1	33%	0	0%	0	0%	0	0%	0	0%	0	0%	2	67%
Submerged Turbine Pump	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Delivery Problem	2	1%	0	0%	1	50%	0	0%	0	0%	0	0%	0	0%	1	0%
Other	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Unknown	178	90%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	178	100%
Totals	198		2		2		1		0		0		0	0	193	

= number, % = percent of total number

If you have site specific or general UST questions or you cannot download this report, please contact the UST Program by calling 404-362-2687.

Note: Release, source and cause information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those USTs identified in 40 CFR 280.10(b) UST's deferred in 40 CFR 280.10(c) and those used for emergency power generation (deferred from release detection by 40 CFR 280.10(d)) are included as part of the public record.

This report reflects data from releases reported to EPD during the time period of the report. Source and cause data were collected using on-site inspections and reports from facilities. The locations of these releases were not identifiable. "OTHER" is an identifiable source that does not fit specific locations identified in the chart.